

Date: 16/06/2021

Sub: Answer to queries raised in the Pre-Bid meeting and submitted through letter by different bidders for the tender “Supply, on-site delivery, installation and commissioning of 70 (Seventy) Nos of Rectifier System (48V, 240A) for BTS Sites under System Operations, Chattogram”.

Ref: Tender no.: 14.35.0000.220.07.008.21/48, dated 07/06/2021

A Pre-Bid meeting for the subject mentioned tender was held on 14/06/2021 at 11:00 AM using Zoom app. Representative of 1) Fast Network Technologies 2) Eltek 3) Radisson Digital Technologies 4) Base Technologies Ltd as well as members of Tender Specification committee have participated in the meeting. In the meeting, queries of the bidders were discussed in detail. Bidders have also submitted the queries through letter. Based on the discussion and submitted letters, answers for some queries are given as follows:

Q.01: Could we consider 6U~8U Solution instead of 3U Solution?

Ans: Original tender document should follow.

Q.02: What will be the specification of 19-inch Rack?

Ans: The 19-inch Rack should be two post open frame rack, which is 42U ~ 45U in height.

Q.03: Who will provide extra cable for AC/DC/Alarm connection, if required?

Ans: Contractor will use existing AC, DC and alarm cable for AC power, battery and alarm connection. Teletalk will provide extra cable if required.

Q.04: Can we Consider the higher current rated module instead of 40A ~ 50A?

Ans: For (48V, 240A) rectifier solution rectifier module should be minimum 40A and maximum 60A (40A ~ 60A).

Q.05: Who will be responsible to send back the existing system (dismantled system) to Teletalk office?

Ans: Teletalk will be responsible to send back the existing system (dismantled system) to Teletalk office.

Clause No-2 of Installation Principle of Rectifier System amended as below:

For Outdoor site: The supplied Rectifier System shall be installed and mounted in 19-inch existing rack and fixed firmly in the rack. In this case the supplied 19-inch rack has to be supplied to System Operations, Chattogram office (Teletalk Bangladesh Limited, Telephone Bhaban-4th Floor, Sk Mozib Road, Agrabad, Chattogram).

Q.06: Can we consider 2 (Two) years warranty period from the installation date instead of PAC date?

Ans: Original tender document should follow.

Direction:

The above answer of queries will be treated as an integral part of the tender schedule. If any contradiction arises between the tender schedule and the answers mentioned above, then above answers will prevail.